



NOTES:

1. WHERE SHEATHING IS USED, A BOND BREAKING MATERIAL IS REQUIRED BETWEEN CONCRETE AND SHEATHING.
2. O.D. IS NOT TO INCLUDE BELL.

LEGEND:

A = D/4 BUT NO LESS THAN 150mm, OR AS DIRECTED BY CITY ENGINEER.

X = ① 100mm MIN. – 150mm MAX. FOR D 900mm or SMALLER.

② 150mm MIN. – 250mm MAX. FOR D 900mm – 1500mm.

③ 250mm MIN. – 300mm MAX. FOR D 1600mm or LARGER.

NOT TO SCALE

CITY OF WINDSOR	
ENGINEERING DEPARTMENT	
BEDDING DETAIL FOR SEWER PIPE CLASS A	
DR'N BY: MP, AZ	DATE: MAR, 1979
REV. DATE: MAR, 2024	CH'KD BY(ENG):PM, JH
CH'KD BY(GEO/OPS):PJU, AL	PASSED BY:FM
_____ CITY ENGINEER	AS-310A