



SECTION A-A

NOTES:

1. ALL MAINTENANCE HOLE COMPONENTS TO MEET AS-314;
2. ALL BENCHING IS TO MEET OPSS 701.21
3. ALL CAST IN PLACE CONCRETE TO BE 32 MPa
4. CONCRETE BONDING AGENT MUST BE APPLIED TO ALL INTERFACES OF PRECAST TO CAST-IN-PLACE CONCRETE.
5. TOP OF EXISTING MAINLINE SEWER MUST BE FULLY REMOVED TO SPRINGLINE ACROSS THE FULL INTERNAL WIDTH OF THE STRUCTURE

**CITY OF WINDSOR
ENGINEERING DEPARTMENT**

DOGHOUSE MANHOLE

| | |
|------------------|------------------|
| DRAWN BY: N.B. | DATE: APRIL 2016 |
| REVISED: - | CHECKED BY: P.U. |
| CHECKED BY: M.C. | PASSED BY: M.W. |

[Signature]
CITY ENGINEER

AS-559