


**NOTES:**

- ①  $A = D_{ix}/4$  BUT NO LESS THAN 150mm, OR AS DIRECTED BY CITY ENGINEER.
- ② CLEAR STONE MAY BE 16mm OR 19mm. REFER TO CITY OF WINDSOR STANDARD SPECIFICATION S-4.
- ③ COVER MUST BE COMPACTED TO 100% SPMD
- ④ IF THE NATIVE, UNDISTURBED SOIL IS A FINE GRAINED, NON-COHESIVE MATERIAL, THE USE OF A GEOTEXTILE FABRIC SEPARATION MAYBE REQUIRED BETWEEN THE NATIVE MATERIAL AND THE SEWER STONE BEDDING MATERIAL

NOT TO SCALE

 <b>CITY OF WINDSOR</b> ENGINEERING DEPARTMENT	
<b>CLASS 'B' BEDDING DETAIL</b> <b>VARIOUS CASES</b>	
DR'N BY: MF, AZ	DATE: MAR, 2004
REV. DATE: JUN, 2024	CH'KD BY(ENG): PM, JH
CH'KD BY(GEO/OPS):PJU, AL	PASSED BY: FM
_____ CITY ENGINEER	<b>AS-310B</b>